

## NOTES:

- ALL CONCRETE TO BE CLASS "A" IN ACCORDANCE WITH SECTION 90, OF STATE STANDARD SPECIFICATIONS.
- BAR REINFORCEMENT SHALL CONFORM TO SEC. 52 OF STATE STANDARD SPECIFICATIONS. MIN. 2" CLEAR FROM FACE OF CONCRETE. VERTICAL LAP SPLICE, 18"MIN.

